

VOC Content Test Certificate

Date: 31/05/2019

Manufacturer: Parchem Construction Supplies Pty Ltd

1956 Dandenong Rd, Clayton VIC 3168

Test Method: ASTM D3960 Standard Practice for Determining Volatile

Organic Compound (VOC) Content of Paints and Related Coatings Materials. ASTM D3960 test method is referred in accordance with the laboratory testing guidance from

Green Building Council of Australia.

| Specification | Fosroc Nitoseal® PU250 |
|-------------------------------------|------------------------|
| Green Building Council of Australia | |
| Green Star Design & As Built V1.3 | |
| Green Star Interiors V1.3 | |
| Result | 104 grams per litre |

Parchem Construction Supplies, part of DuluxGroup and the licensed manufacturer and distributor of Fosroc products in Australia, is proud to be a member of the Green Building Council of Australia. Environmental sustainability is a core element of the DuluxGroup business philosophy.

Parchem is an ISO9001 accredited organisation.

Martin Venn

Technical Support Manager

Fosroc, Cemtop, Conbextra, Concure, Dekguard, Nitoflor, Nitoseal, Proofex, Renderoc, Supercast, Thioflex and the Fosroc logo, are the trade marks of Fosroc International Limited, used under licence.

Parchem, DuluxGroup, and the Squares Device are registered trade marks





